

ISOflanges GmbH – Winsen (Aller)

Analysis of Hazards and Risks / Instructions for Operation and Use

Insulating Flange Connection Type HP / HP2 (High Performance)




Figure 1: Example of installation with cable lug and spark gap



[Installation video](#)

[Homepage](#)



Inhaltsverzeichnis

1	Analysis of hazards and risks.....	3
1.1	General information.....	3
1.2	Hazard analysis.....	3
2	Instructions for operation and use	5
2.1	Introduction	5
2.2	Data on the nameplate	5
2.2.1	Attachment of type plate for black/white connections type SW5.....	5
2.3	Design and installation/assembly	6
2.3.1	Preparation of the installation on site	6
2.3.2	Assembly instructions	6
2.3.3	Assembly of flanged joints	6
2.3.4	Installation of cable lugs and explosion spark gap.....	8
2.3.5	Assembly of shim rings/compression rings/insulation rings.....	9
2.4	Commissioning.....	11
2.5	Use and operation.....	11
2.5.1	Operating conditions of the insulating flanged joints.....	11
2.5.2	Painting of the insulated flange connections.....	12
2.5.3	Bolt insulation	12
2.5.4	Bolt coating/Corrosion protection	12
2.5.5	2.5.5. Torque calculation.....	13
2.6	Maintenance and inspection	13
2.7	Documentation	13
2.8	Dismantling/disposal.....	14

1 Analysis of hazards and risks

1.1 General information

The hazards and risks analysed in this document must be strictly observed and the instructions must be followed prior to use and/or installation.

1.2 Hazard analysis

If the product is used properly, no hazard is to be assumed.

Hazard analysis HP/HP2 insulating flange connection

Hazard	Possibility	Explanation	Measure
1. Exceeding the max. permitted internal or external pressure	Yes	Max. operating pressure is indicated on the name plate; information in the operating instructions	The operator is responsible not to exceed the max. permitted pressure
2. Exceeding the max. or min. permitted temperatures or the temperature gradient	Yes	Max./min. operating temperature is indicated on the name plate; information in the operating instructions	The operator is responsible not to exceed the max. permitted temperature ranges
3. Exceeding the design features relevant for the lifecycle of the device with respect to creep effects, fatigue and corrosion	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
4. Hazards due to the static pressure and device content under operating and test conditions	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
5. Exceeding the static load and the traffic, wind, snow or earthquake loads	n/a	/	/
6. Exceeding of reactive forces and moments resulting from supports, fittings and pipelines etc.	n/a	/	/
7. Decomposition of unstable fluids	n/a	/	/
8. Aspects of instability	n/a	/	/
9. Faulty handling of closures and openings	No	Note in the operating instructions: To be installed by qualified personnel only	/
10. Dangerous unloading of pressure relief valves	n/a	/	/
11. Faulty handling of devices to avoid physical access in the event of overpressure or vacuum	n/a	/	/
12. Surface temperature in consideration of the intended use	No	Max./min. operating temperature is indicated on the name plate; information in the operating instructions	/
13. Faulty handling of unstable fluids leading to their decomposition	n/a	/	/
14. Faulty drainage and ventilation with the following possible consequences:			
14.1. Water hammer, implosion, corrosion and chemical reactions	n/a	/	/
14.2. Obstruction of safe cleaning, inspection and maintenance	n/a	/	/

Hazard analysis HP/HP2 insulating flange connection

Hazard	Possibility	Explanation	Measure
15. Excessive wear	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
16. Faulty assembly of components	Yes	Note in the operating instructions: To be installed by qualified personnel only	The operator must use qualified personnel and observe the operating instructions
17. Faulty filling and drainage			
17.1. Overfilling or exceeding the permitted pressure	Yes	Max. operating pressure is indicated on the name plate; information in the operating instructions	The operator is responsible not to exceed the max. permitted pressure
17.2. Instability of the pressure device	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
17.3. Uncontrolled escape of the fluid under pressure	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
17.4. Unsafe connection and separation	Yes	Note in the operating instructions: To be removed by qualified personnel only	The operator must use qualified personnel and observe the operating instructions
18. Inappropriate failure of equipment parts with safety function, of devices for pressure limitation or temperature monitoring, e.g. with respect to:			
18.1. Reliability for the intended use	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
18.2. Maintenance and test requirements	No	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
18.3. Independence of other functions	Yes	HP/HP2 insulating flanges are permanently sealed and mechanically maintenance-free	/
19. Inappropriate failure of measures against fire from outside	No	HP/HP2 insulating flanges are not resistant against fire from outside	The operator must specify measures in the fire protection concept / safety concept

2 Instructions for operation and use

2.1 Introduction

The insulating flange connection type HP/HP2 is used for the safe electrical separation of steel pipes in connection with a CCP system (cathodic corrosion protection system) and in “black and white connections” to protect bimetallic corrosion. The insulating flange connection is suitable for gaseous media (also for gases according to G 260) and liquid media and is designed in such a way that it can withstand the usual operating loads without any problems (provided it is installed correctly) and fully complies with its functional capability. It is not necessary to disassemble the insulating flange connection during the pressure test (test pressure max. 1.5xDP) of the pipeline, the insulating flange connection can remain in the pipeline. In contrast to other insulating flange systems available on the market up to now, the HP/HP2 system is state of the art, mechanically maintenance-free, technically tight in the long term in accordance with TRBS 2141-3 and TRBS 2152-2, mechanically resistant to additional pipe forces and allows the maximum permissible utilisation of the bolts (> 70% Rp0.2).

2.2 Data on the nameplate

The identification of the insulating flange connection consists of a weatherproof, permanent type plate, which is glued to the circumference of the hard fabric flange. As additional protection, the nameplate is provided with a laminate which is UV-resistant and protects against various external influences, as well as liquids and moisture. In the assembly of the insulation flange connection it is important that the insulating flange is positioned for the nameplate to be well visible and easily readable. The insulating flange connection is marked as follows (example):

Manufacturer; nominal size; design pressure; operating pressure; temperature; torque; CE-conform; year of manufacture; serial No.:



HQ DN 50 PN 10-40 PS 40bar TS -20°C/+60°C 116Nm C € 0045 2024 C0123.456
Anzugsdrehmoment: 116 Nm Artikelnummer: 81100015

2.2.1 Attachment of type plate for black/white connections type SW5

Only the individual parts are verified for the black/white connections type SW5 and there is no obligation to provide a type plate. Nevertheless, we supply a type plate with details of the temperature range, year of manufacture and tightening torques. This must be affixed by the customer to the welding neck flange directly adjacent to the connection.

Analysis of the hazards and risks

The nameplate must be handled with care and must be protected against damage and external mechanical forces that reduce the legibility of the nameplate.

If this is not observed, proper identification or allocation to the Acceptance test certificate is no longer possible and there is a risk of loss of the approval.

2.3 Design and installation/assembly

In addition to these installation instructions, the quick guide enclosed with the delivery must also be observed.

2.3.1 Preparation of the installation on site

- Comparison of the planning documents with the on-site situation
- Inspection of the parts intended for installation
- Selection of suitable tools

Analysis of the hazards and risks

In case of non-observance, as well as when mounting dirty or damaged components, the electrically insulating function of the insulating flange connection is not guaranteed. There is danger to people and the environment.

2.3.2 Assembly instructions

- A flange connection can only fulfil its function safely if the elements of the flange connection, correctly dimensioned for the intended use, are also correctly installed.
- Seals must be visually inspected before use and must not be reused after installation.
- Sealing surfaces must be clean, free of residues, undamaged and free of grease. This also applies to the groove of the insulating flange.
- Flanges must be able to be joined flush and smoothly without the application of force.
- Assembly must generally be carried out using suitable torque-monitoring tools. These tightening torques only apply on condition that the threads of the stud bolts and the contact surfaces of the nuts have been treated with suitable lubricants for this purpose (lubrication of the force-transmitting components). In the case of the bolts used, this is achieved by means of the self-lubricating zinc flake coating. **No additional lubricant is required.**
- Spare parts may only be obtained from the manufacturer.

2.3.3 Assembly of flanged joints

- The screw bolts are provided with a self-lubricating coating – no lubrication or greasing is required.
- If an additional lubricant has been applied by the operator, then the operator must ensure that the friction value of $\mu_{ges} = 0.12$ is maintained. Better or worse friction values can lead to failure of the flange connection and are therefore the responsibility of the operator.
- The insulating properties of the materials used may be impaired by additionally applied lubricant, resulting in insufficient insulation values.
- No grease or screw pastes may be applied to the seal or the sealing surface.
- The components must not be mounted in a dirty condition. The insulating flange connections and their individual components must be dry and clean before assembly.
- Bolted connections on flanges must not be tightened under operating pressure. Leaking flange connections must be reassembled, using new gaskets.
- Seals, bolts and nuts must be treated accordingly as safety-relevant components.

- The insulated studs must be installed in such a way that the stud insulation is located in the centre of the flange connection and the stud has an equally large projection on both sides of the welding neck flanges. The stud insulation protrudes from the welding neck flange, so that the insulation ring still to be fitted covers the protruding stud insulation. The bolt projection is dimensioned with a maximum projection of one thread turn ($1 \times p$) plus the thread run-out ($1 \times z_1$). The smallest possible bolt projection corresponds to the thread run-out. We use H=D nuts for all insulating flange connections, according to DIN 2510 NF. The indicated bolt protrusion corresponds to the state of the art.
- To ensure that the flanges are aligned, the self-lubricating bolts must be used in the lower area of vertically aligned flanges.
- In order to ensure a professional and stress-free assembly of the flange connections, the correct sequence must be planned/defined before starting the work. The stress-free installation of the insulating flange connection is a prerequisite for proper functioning.

Tightening the bolts is done in at least 5 steps:

- Step 1: approx. 10 - 20% of the assembly tightening torque (crosswise)
- Step 2: Check that the flange connection is flush and smooth so that the sealing surfaces are evenly seated on the gasket
- Step 3: approx. 50 - 70% of the assembly tightening torque (crosswise)
- Step 4: 100% of the assembly tightening torque (crosswise)
- Step 5: 100% of the assembly tightening torque (all around)
- Alternative approved methods for tightening the bolts are also permitted in individual cases.




Figure 2: Tightening sequence of the bolts

2.3.4 Installation of cable lugs and explosion spark gap

The pair of cable lugs consists of two components (see Figure 4). The contact surface of the cable lug must be metallically bright and sealed with pole grease. There must be no residues of paint, corrosion build-up or other coatings under the cable lug. The cable lugs must be mounted as shown in Figure 3 and safe conductivity must be established.




Figure 3




Figure 4

When installing explosion isolating spark gaps, the associated installation instructions must be observed and complied with. The Ex isolating spark gaps are mounted on the supplied cable lugs as shown in Figure 3.

2.3.5 Assembly of shim rings/compression rings/insulation rings




Figure 5: Cross-section of insulating flange connection HP2

Flange compensation rings (item 10)

- In order to ensure the correct operation and tightness of the insulating flange connection, it is imperative that the flanges used comply with the applicable standards for which the insulating flange connection is designed.
- Due to the large tolerances in the standards for the height of the sealing strip, it must be ensured that the height of the sealing strip of the welding neck flange is not lower than 0.3mm or max. not higher than the height of the sealing strip, f_1 , specified in the standard. If necessary, the height of the sealing face of the welding neck flange must be checked.
- The thickness of the compensation ring is equal to the height of the sealing strip (f_1), or 0.3 mm less. If the sealing strip is lower than $f_1 - 0.3\text{mm}$, the seal is not pressed sufficiently – the connection is not tight.
- The thickness of the compensating rings is selected to give the same height as the sealing strip or a height difference of max. 0.3mm overhang for the sealing strip (Figure 7).
- This results in a block flange system, a bending of the welding neck flange during assembly is prevented and the surface pressure is evenly applied to the insulating rings and hard fabric flanges.
- The flange compensation rings must be fitted as shown in Figure 7.



Figure 6: Flange compensation rings




Figure 7: Flange compensation ring assembly

- If the thickness of the compensating ring supplied with the insulating flange connection does not match the height of the sealing strip of the existing welding neck flange, we have compensating ring sets in our range of products.

Pressure rings (Pos.3):

- The pressure rings consist of 2 components of equal size. They are to be mounted 90° offset to the insulating rings (see figure 8). The pressure rings transfer the surface pressure from the screw forces to the insulating rings and must not be changed in any way.




Figure 8: Alignment of the pressure ring and the insulating ring

Insulating rings (Pos.4):

- The insulating rings are mounted between the flange and the thrust collar as shown in Figure 5.
- When installing insulating flange connections in a horizontal piping, it is important that the gap between the two halves of the insulating rings is oriented vertically (6 o'clock). This ensures that moisture can drain off and prevents the accumulation of water (electrolyte) that could lead to a bypass of the electrical insulation.

Note: In addition to the operating instructions, you can find our installation video on YouTube under the following link: <https://youtu.be/SPMF2u2mIXU>

2.4 Commissioning

A risk assessment must be available before starting work. This is not included in the scope of delivery and must be created by the customer. According to BetrSichV (Industrial safety regulations), the requirements to be met for occupational health and safety as well as for plant safety must be specified. Essential organisational requirements include:

- Flanged joints must always be designed and calculated according to the intended use.
- The assembly of the flange connections may only be carried out by qualified assembly personnel in accordance with BetrSichV §2 and §10.
- The tightening procedure and the tightening torque or pretensioning force of the bolts must be specified for the assembly personnel (see documentation drawing).
- The instructions for use and operation must be made available to the installation personnel.
- Only approved and suitable tools may be used.
- No changes whatsoever may be made to the insulating flange connection as a whole or to individual components. Only materials supplied by the manufacturer may be installed.

Analysis of the hazards and risks

The safety instructions must be observed.

If the safety instructions are not observed, the safety and health of the personnel and also the functionality of the component is at risk.

2.5 Use and operation

2.5.1 Operating conditions of the insulating flanged joints

- This document applies to the installation of insulating flange connections, type HP2 from ISOflanges GmbH at ambient temperatures from -20°C to +60°C (or the temperatures specified in the documentation). The minimum/maximum operating temperature must not be exceeded or undercut.
- The instructions are to be used when mounting and dismounting metallic flanged joints on pipelines and pressure equipment. A flange connection is a detachable connection between apparatus, pressure equipment, machine or pipeline elements.
- Pipelines to be connected may only be installed and operated free of forces and torques.
- In order to ensure the correct operation and tightness of the insulating flange connection, it is imperative that the flanges used comply with the applicable standards for which the insulating flange connection is designed. See also description "Spacer ring" p. 8/12. The thickness of the spacer rings is equal to the height of the sealing strip, or max. 0.3 mm less than the sealing strip.
- The maximum permissible operating pressure is stated in the attached inspection certificate and must not be exceeded.
- Before installation, the components must be checked for perfect condition, only undamaged components may be installed.
- The components of the insulating flange connection as well as the tools to be used must be stored properly and/or be suitable and calibrated.
- The compatibility between the medium and the insulating flange connection or the sealing material is the responsibility of the operator.

- Static operation was assumed for the pressurising equipment part and it may only be operated in such a way that no fatigue stress occurs. (Max. 1000 load cycles with $\Delta P = PS$ and any number of load cycles with $\Delta P = PS/10$ (see AD 2000 data sheet S1 section 1.4)).
- The flanges of the connecting pipework (with socket wall thickness $s_{min} = xx$ mm) must be specified by the operator and it must be guaranteed by the operator that these are designed for the maximum operating pressure.

Analysis of the hazards and risks

If the sealing face is lower than the balancing ring, the latter must be adjusted. Assembly without adjustment is not permitted because the tightness cannot be guaranteed. Non-compliance with these operating instructions may endanger people and the environment. No liability is assumed for damage of any kind resulting from non-compliance with this document.

2.5.2 Painting of the insulated flange connections

When delivered, the insulating flange is painted in a signal colour (orange) so that it can be easily recognised as an insulation separation point and to protect the material from weathering.

The paint consists of a 2K polyurethane acrylic paint and has the following properties:

- high UV and weather resistance
- very good water resistance
- resistant to solvents
- continuous temperature load: 150 °C

The insulating flange connection must not be painted over in any form. This would mean the loss of functionality and warranty.

2.5.3 Bolt insulation

Care must be taken that the insulation is not damaged. There must be no spalling, cracks or other damage. The screw bolts must be carefully protected against damage. If there is any damage, the bolts must not be used any more. Spare parts may only be obtained from the manufacturer.

The flanges must be joined flush and smoothly. Flange blades with parallel alignment and no centre offset are required for correct installation. Care must be taken to ensure that the bolts can be passed through the bolt holes in the flanges without damaging the insulation by the edges of the holes. No torsional forces must be applied to the screw bolts. The screw bolts must not be turned in the screw holes.

Analysis of the hazards and risks

If this is not observed, damage to the electrically insulating bolt insulation is possible and thus the function of the insulating flange connection cannot be guaranteed.

2.5.4 Bolt coating/Corrosion protection

- The self-lubricating coating of bolts and nuts consists of a zinc flake coating as priming coat and a solvent-based cover coat. Defined friction coefficient $\mu_{ges} = 0,12$.

- If an additional lubricant has been applied by the operator, then the operator must ensure that the friction value of $\mu_{ges} = 0.12$ is maintained. Better or worse friction values can lead to failure of the flange connection and are therefore the responsibility of the operator.
The insulating properties of the materials used may be impaired by additionally applied lubricant, resulting in insufficient insulation values.
- To keep the coating properties, the surface must never be brought into contact with any cleaning agents, dilutants or other agents that could potentially harm a solvent-based surface.
- The procedure of zinc flake coating is described in the norms DIN EN ISO 10683 and DIN EN ISO 13858.

Corrosion resistance DIN EN ISO 9227 / ASTM B117

guarantees cathodic corrosion resistance as required in DIN EN ISO 10683 and passes the salt spray test DIN EN ISO 9227 and required in DIN EN ISO 10683.

Analysis of the hazards and risks

It has to be ensured that the coating is not brought into contact with cleaning agents, dilutants or other agents (that could potentially harm a solvent-based surface). If this is not observed, damage to the coating is possible, leading to corrosion.

2.5.5 Torque calculation

The flange connection has to meet certain defined tightness requirements depending on the application. A mathematical tightness and strength verification for the system is carried out according to DIN EN 1591-1. The torque to be applied is supplied by ISOflanges and is noted on the documentation drawing.

The insulating flange connection may only be tightened to this torque. For mounting and applying the torque, the mounting instructions listed must be observed.

The calculation of the torque is done at a friction coefficient of 0.12 and refers to the components supplied by ISOflanges.

The flanges according to DIN EN 1092-1 or ASME B16.5, which are not included in the scope of delivery, are included in the calculation with standard materials. These materials are: P235GH, P250GH, P355QH1, C22.8, C21. Materials providing equal physical properties are taken into account as well and can be tightened with the same torque. If other flanges with deviating physical properties are used, an adapted mathematical verification is required.

2.6 Maintenance and inspection

The insulating flange connections type HP2 from ISOflanges are mechanically maintenance-free.

2.7 Documentation

The associated documentation is issued by ISOflanges and is part of the insulating flange. The insulating flange must not be operated without documentation.

- EU Declaration of Conformity ISOflanges GmbH
or Certificate of conformity by TÜV NORD Systems GmbH & Co. KG

- APZ 3.1 according to DIN EN 1594 or test report of the acceptance from TÜV Nord
- Documentation drawing
- Operating Instructions / Hazard analysis / Installation instructions

The certificates of the individual components are documented and archived by the manufacturer, but are not part of the delivery. The conformity of the complete component according to PED is certified by the manufacturer according to the declaration of conformity.

2.8 Dismantling/disposal

As a basic principle, only unpressurised and drained pipes and plant components may be opened. For this purpose, the system must be taken out of operation properly before disassembly.

When the flanges are cleaned, the insulating flange connection can be fitted with a new gasket. Seals are generally to be used only once. Bolts and nuts intended for reinstallation must be checked for suitability and replaced if necessary. The bolt insulation must be undamaged.

Spare parts may only be obtained from the manufacturer.

After disassembly, the components must be inspected/evaluated for contamination and disposed of accordingly/ properly.

Analysis of the hazards and risks

If the operating instructions and notes are not observed, the electrically insulating and mechanical function of the insulating flange connection is not guaranteed. No liability or warranty is accepted for damage of any kind.

ISOflanges is certified according to the Pressure Equipment Directive (PED) in Category 3, Module H.

ISOflanges is certified according to: ISO 9001:2015, Design and sale of technical components for gas technical installations.

You can reach our sales and service department:

ISOflanges GmbH

Viehtrift 1

29308 Winsen

Tel: +49 5143 92 34 9 - 0

Mail: info@isoflanges.de

www.isoflanges.de